

June 27, 2023

MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/454-8049

ADDENDUM NUMBER 4
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: 2023 Saferoom Addition for MacArthur Early Childhood Center

FOR: Macomb CUSD No. 185
323 W. Washington Street
Macomb, IL 61455

A/E PROJECT NO: 2592 0221

ISSUE DATE: June 1, 2023

BID OPENING: Friday, June 30, 2023, 2:00 p.m., prevailing time
323 W. Washington Street, Macomb, IL 61455

THIS ADDENDUM DOES NOT CHANGE THE BID DATE OR BID TIME.

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. THIS ADDENDUM DOES NOT CHANGE THE BID DATE.

10. TO THE DRAWINGS: Sheet A-1 Door Schedule: Add hardware descriptions:

- a. Locksets: Cylindrical, extra heavy duty Schlage, Corbin, Sargent, Mark, or equivalent. ANSI 156.2 Grade 1 vandal resistant keying, coordinate with building. Lever to be selected.
- b. Closers: Norton 7500, Sargent 350, LCN4041 series, thumb turn adjustable hold open arm unless noted to hold open.
- c. Door Stops: Glynn Johnson WB50MX, Ives #401 or equal.
- d. Kick Plates: 16 gauge stainless steel 8"x2" less than door width, bevel edge 3 sides, flat head screws.
- e. Hinges: ANSI A5112, 4 ½ x 4 ½ brushed stainless steel, Hager BB1279 or similar.
- f. Finish: US26D/BHMA 626, US32D/BHMA630, US28/BHMA 628 allowed on aluminum items.
- g. Aluminum door hardware is noted in 08 1140, 3.2.

END ADDENDUM NO. 4